



INVITATION TO BID

The City of Paris will receive proposals until 2:00 PM on Monday, May 19th, 2025, for a new or used bypass pump. Specifications and other related information may be obtained from the undersigned at 525 High Street, Paris, KY 40361, during normal working hours or by visiting the City of Paris website:
<https://paris.ky.gov/CurrentBidOpenings.aspx>

Sealed bids should be delivered to the attention of the City of Paris Purchasing Manager no later than Monday, May 19, 2025 at 2:00 PM. Bids shall be clearly marked "WWTP Bypass Pump". The City reserves the right to reject any and all proposals.

Michael Harris, Superintendent
Waste Water Treatment Plant
525 High Street
Paris, KY 40361
(859) 987-2110
mharris@paris.ky.gov

Specifications

6 inch suction

6 inch discharge

2000-2500 gpm

2000-2500 rpm operating speed

able to pass 3 inch solids

maximum operating pressure of at least 50 psi

maximum head of at least 125 ft