



INVITATION TO BID

The City of Paris will receive proposals until 10:00 AM on Wednesday, May 28th, 2025, for the conversion of a lift station from a dry pump pit to a submersible pump pit. Specifications and other related information may be obtained from the undersigned at 525 High Street, Paris, KY 40361, during normal working hours or by visiting the City of Paris website: <https://paris.ky.gov/CurrentBidOpenings.aspx>

Sealed bids should be delivered to the attention of the City of Paris Purchasing Manager no later than Wednesday, May 28th, 2025 at 10:00 AM. Bids shall be clearly marked "WWTP Lift Station Conversion". The City reserves the right to reject any and all proposals.

Michael Harris, Superintendent
Waste Water Treatment Plant
525 High Street
Paris, KY 40361
(859) 987-2110
mharris@paris.ky.gov

Specifications

These are the plans that each looked at using:

- Reuse existing wet well for new pumps.
- New precast wet well top with aluminum hatch.
- New 230 V 3 phase electrical service. Paris to provide 230 service drop to new service pole.
- New precast valve vault with check valves, plug valves, emergency bypass pump connection, aluminum hatch.
- KSB pumps rated for 100 GPM @ 68" TDH, Nema 4X SS control panel, floats for level control.
- Old dry pit to be cut off 1' below grade and filled with stone.
- Final grade and seed disturbed areas.
- Bypass pump during change over.