



## **INVITATION TO BID**

The City of Paris will receive proposals until 10:00 AM on Thursday, September 26th, 2024, for a 1000kVA padmount transformer to service its water treatment plant. Specifications and other related information may be obtained from the undersigned at 525 High Street, Paris, KY 40361, during normal working hours or by visiting the City of Paris website: <https://paris.ky.gov/CurrentBidOpenings.aspx>

Sealed bids should be delivered to the attention of the Paris City Clerk no later than Thursday, September 26, 2024, at 10:00 a.m. Bids shall be clearly marked "2024 Water Plant Transformer". The City reserves the right to reject any and all proposals.

Aaron Sparkman, Superintendent  
Electric Department  
525 High Street  
Paris, KY 40361  
(859) 987-2122  
[asparkman@paris.ky.gov](mailto:asparkman@paris.ky.gov)



## 2024 Water Treatment Plant Padmount Transformer

The following list of specifications are the minimum acceptable requirements to be considered for the padmount transformer. Any bid should specify construction/lead times and delivery charges if not included in the price. Please include warranty information in the submittal.

- 1000kVA three phase padmount transformer
- HV: Dual voltage input: 12470Y/7200: 4160Y/2400
- LV: 480Y/277
- Supported 6-position nema 2-hole spade terminals on secondary(see example pic below)
- No LV taps specified, but allowed
- Loop feed HV
- Dead front
- **FR3 OIL**

