


VERTICAL BENDS

| VERTICAL BEND & STRAIGHT PIPE | | | | | | | |
|-------------------------------|-----|-----|-----|-----|-----|-----|-----|
| SIZE | 2" | 3" | 4" | 6" | 8" | 10" | 12" |
| D | 15" | 15" | 15" | 15" | 15" | 18" | 18" |
| L | 12" | 18" | 18" | 24" | 24" | 30" | 30" |

NOTE: ANCHORS TO BE FULL WIDTH OF TRENCH.
ANCHORS MUST BE PLACED AGAINST UNDISTURBED EARTH.



STRAIGHT PIPE



Quest Engineers, Inc.
Lexington, Kentucky
Louisville, Kentucky

CITY OF PARIS, KENTUCKY
WATER DISTRIBUTION DEPARTMENT

WD-4
CONCRETE ANCHOR BLOCK

11-15-91 ISSUE DATE

NOT TO SCALE